

39380



8813 Hwy 41 South  
 Riverview, FL  
 Telephone: (813) 677-9111 - TELX52666  
 Fax: (813) 671-6283 ACCOUNTING

This product was produced at the  
 Production Plant - Riverview facility

CAR NO: SHPX206888

Deliveries: 1001375946

Material: Our / Your reference  
 200011 FLUOROSILICIC ACID /

**Quality Certificate**

Date  
 05/13/2013  
 Purchase order item/date  
 45410951 / 05/01/2013  
 Delivery item/date  
 1001375946 000010 / 05/02/2013  
 Order item/date  
 1544965 000010 / 05/01/2013  
 Customer number  
 5002715

Inspection lot 100000058710 from 05/02/2013

Characteristic	Result	Unit
<b>Chemical Analysis</b>		
Net H <sub>2</sub> SiF <sub>6</sub>	24.92	%
P <sub>2</sub> O <sub>5</sub>	0.10	%
Free Acid	0.36	%
Lead	0.00	ppm
Arsenic	46.75	ppm
<b>Physical Analysis</b>		
Specific Gravity	1.2290	g/cm <sup>3</sup>
APHA	30	CU

"We certify that product shipped with this  
 Certificate of Analysis meets AWWA B703-11"



Certified to ANSI/NSF 60	Max. Use: 6 mg/L
-----------------------------	---------------------

Kwasi Sakyi-Amfo  
 QC Lab Supervisor - Riverview